

### PIPE SUPPORT DETAIL

ISOLATION VALVE

### ROADWAY UTILITY ADJUSTMENT

GENERAL ADJUSTMENT NOTES:

1. THE HIGHEST POINT ON THE CASING, RING, OR COVER SHALL BE NO LESS THAN FLUSH AND NO MORE THAN 1/8" BELOW ASPHALT SURFACE.
2. COMMERCIAL CONCRETE COLLAR MUST BE GIVEN 3 DAYS CURE TIME PRIOR TO ASPHALT CAP PLACEMENT. TIME MAY BE REDUCED WITH ENGINEER APPROVAL.
3. REMOVE ASPHALT AS NECESSARY IN CIRCULAR PATTERN WITH A MINIMUM OF 8 EDGES.

## PLAN

### ELEVATION

## PIPE RESTRAINT

### LADDER DETAIL FOR ELECTROMAGNETIC METER

# STANDARD DETAIL ELECTROMAGNETIC SEWAGE FLOW METER DETAILS



SCALE: AS SHOWN NA	DATE DRAWN	REVISIONS	
		DATE	INITIAL
DESIGNED	CHECKED	12/21/2020	CAW
APPROVED BY	DATE APPROVED	01/01/2022	AJS
STANDARD SPECIFICATIONS			

DETAIL NO.  
S-320B